



Product Service

CERTIFICATE


No. Z2 17 07 99333 009

Holder of Certificate: **LONGi Green Energy Technology Co., Ltd.**

No. 388, Middle Hangtian Road
Chang'an District
710100 Xi'an City, Shaanxi
PEOPLE'S REPUBLIC OF CHINA



Certification Mark:



Product:

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704061601024-01

Valid until: 2022-07-20



Date, 2017-07-31

(Zhulin Zhang)

Page 1 of 2



Product Service

CERTIFICATE**No. Z2 17 07 99333 009****Model(s):**

LR6-72-xxxM, (xxx=320 to 350 in step of 5)
 LR6-60-xxxM, (xxx=270 to 300 in step of 5)
 LR6-72PE-xxxM, (xxx=340 to 375 in step of 5)
 LR6-60PE-xxxM, (xxx=280 to 310 in step of 5)
 xxx is standing for rated output power at STC.

Parameters:

Rated Output Power
 at STC:

320 W, 325 W, 330 W, 335 W,
 340 W, 345 W, 350 W, 270 W,
 275 W, 280 W, 285 W, 290 W,
 295 W, 300 W, 340 W, 345 W,
 350 W, 355 W, 360 W, 365 W,
 370 W, 375 W, 280 W, 285 W,
 290 W, 295 W, 300 W, 305 W,
 310 W.

Severity of

Salt Mist Test:

Severity 6

Application Class:

Class A

Maximum System Voltage:

1000 V DC

Fire Safety Class:

Class C

Construction:

Framed, with Junction box,
 Cable and Connectors.

**Tested
according to:**

IEC 61215(ed.2)
 IEC 61730-1(ed.1);am1;am2
 IEC 61730-2(ed.1);am1
 IEC 61701(ed.2)

**Production
Facility(ies):**

99605, 99606, 99626, 90968, 01192