

# Quick guide: Setting Grid Parameters according to AS/NZS 4777.2:2015\*

\*According to network operators requirements on Fronius SnapINverters Galvo, Primo, Symo, Eco



White Paper

© Fronius Australia Pty Ltd., VH

Version 1.0/2015

Fronius reserves all rights, in particular rights of reproduction, distribution and translation.

No part of this work may be reproduced in any way without the written consent of Fronius. It must not be saved, edited, reproduced or distributed using any electrical or electronic system.

You are hereby reminded that the information published in this document, despite exercising the greatest of care in its preparation, is subject to change and that neither the author nor Fronius can accept any legal liability Gender-specific wording refers equally to female and male form.

(c) Fronius Australia Pty. Ltd, 2015



#### 1 GENERAL

The Fronius SnaplNverter range of inverters delivered to Australia are designed to have the country specific setup activated upon installation of the inverter. All inverters installed in Australia should be set to country setup "AU" upon commissioning.

The current settings embedded in the country setup "AU" conform to the older but still current AS4777.3:2005 Standard, Clause 6.3.

There are however some DNSP's (utilities) that request the settings to meet the new AS/NZS 4777.2:2015 Standard or have their own network specific grid protection settings. Some also request the activation of power quality functions of the inverter such as Reactive Power Control.

This document provides a "quick guide" on how to set the voltage protection & reactive power settings located in the hidden Service Menus according to the requirements requested by distribution network providers (DSNP). For more detailed information regarding the Service Menu settings, please request the Service Menu Manual from Fronius Australia Technical Support.

The hidden Service Menus on the Fronius SnapINverters (Galvo, Primo, Symo, ECO) are accessed via the inverter's display with use of a password. The voltage & reactive power settings are a part of the 'PROFI' service menu and require the use of a <u>password that is issued by Fronius Technical Support</u> upon the completion of the "*Request\_for\_Access\_code\_Grid\_parameters\_Fronius\_Inverters*" form. Once this form has been completed and logged, Fronius Technical Support will issue the password.

Fronius Australia Technical Support

Email: PV-Support-Australia@fronius.com

Phone: 03 8340 2910

#### Note!

Any altered grid parameter settings need to be approved by the corresponding DSNP!

# 2 SETTINGS

Before performing the following settings the inverter <u>must</u> have to have the latest software version installed. The latest USB version for all the SnaplNverter range can be downloaded from the Fronius website here: <a href="http://www.fronius.com/cps/rde/xchg/SID-D8B2A594-F670E8D4/fronius\_australia/hs.xsl/25\_7671.htm">http://www.fronius.com/cps/rde/xchg/SID-D8B2A594-F670E8D4/fronius\_australia/hs.xsl/25\_7671.htm</a>

In some cases the Country Setup will need to be re-loaded after the software update is completed.

#### 2.1 Enter the hidden 'PROFI' menu



(c) Fronius Australia Pty. Ltd, 2015 3/6



Type in the access code for the hidden **PROFI** menu\*




<sup>\*</sup>Available only upon request from Fronius Technical Support.

## 2.2 Setting max Voltage limits according to AS/NZS 4777.2:2015

Fronius inverters provide grid voltage settings in 3 stages, therefore the following voltage limits can be set

- Stage 1, max overvoltage 260V, trip time 1 2 sec
- Stage 2, max overvoltage 265V, trip time 0.2 sec
- Stage 3, max sustained voltage 258V, trip time 3 sec (10 min average voltage limit)

Stage 1: Go to tab "U Inner Limit Max" and enter 260V





Go to tab "U IL Max TripTime" and enter 100cyl (cycles)





Stage 2: Go to tab "U Outer Limit Max" and enter 265V





(c) Fronius Australia Pty. Ltd, 2015 4/6



### Go to tab "U OL Max TripTime" and enter 10cyl (cycles)





Stage 3: Go to tab "U Longtime Limit" and enter 258V

The new 10 minutes average voltage setting was introduced due to the new AS/NZS 4777.2 which can be found under tab "U Longtime Limit".






Set the max voltage limit according to the DNSP's requirements


# 2.3 Setting a fixed power factor

Go to menu tab "Reactive Power Mode"



Under the menu tab "React. P. Mode" select " $\textit{C. Cos}\phi$ " (= constant cos phi) and press enter.





(c) Fronius Australia Pty. Ltd, 2015 5/6



Under the menu tab " $C. Cos \varphi$ " set the required value.





- + .... Leading value
- .... Lagging value

For more detailed information see the operation manual available on the product specific page on <a href="https://www.fronius.com.au">www.fronius.com.au</a>

(c) Fronius Australia Pty. Ltd, 2015